City of Hiawatha!
Public Works

Memo

To: Mayor, City Admin and City Council

From: Rod Jasa

Date: July 13, 2017

Re: June Public Works Report

Streets – We removed over 20 dead trees in the Right Of Way on Boyson Rd. We started our street painting. We worked on the Center Point Rd irrigation to get it up and running. We did the usual mowing and pothole filling. Vehicles serviced: 770, 820, 860, 300, 310, 580. 850, 720, 730.

Sewer – Mitchell Dr. lift station had an issue with a relay in Pump 1 control panel and was not sending me the correct data. I had Electric Pump fix it. We also replaced the battery in the Springbrook lift station. All lift stations are now working correctly.

Storm Water – We worked with REC and repaired a PVC storm water pipe that had a power cable running through it on Savannah Dr.

Actual hours worked by Public Works employees in each department. Leave with pay hours are not included.

	Streets 21010		Snow 25010		Parks 43010		Sewer 81510		Water 81010		Storm Water	City Hall
	Reg	OT	Reg	OT	Reg	OT	Reg	OT	Reg	OT	Reg	
Total	812				38		22				37	

Submitted by:

Rod Jasa