



Notes:

1. This detail applies for service stop boxes in driveway and paved parking areas
2. This detail applies for both PCC or HMA pavements
3. Match slope of final grade and center service stop box under lid
4. Shut-off valve to be 2-inches below lid
5. Pavement and Compacted Base thickness per plans

A Y McDonald Valve Box 5601
w/SS Operating Rod or Stem
Minimum Length 42-inches

Installation Limits:

D. 3' Minimum to 5'
Maximum





